

**PINES LAKE ELEMENTARY  
511 PINES LAKE DRIVE**

Test Date - 10/7/16 & 10/11/16 & 10/13/16

**KEY:**

**TNR: Testing Not Required  
ND: None Detected      BS: Below DEP/EPA Standard  
DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION**

<b>SAMPLE NUMBER</b>	<b>DESCRIPTION</b>	<b>TEST RESULTS</b>	<b>NOTES</b>
L6439858-1	CLASSROOM 27 SINK	0.011	TNR/BS
L6439858-2	CLASSROOM 6 SINK	ND	TNR
L6439858-3	CLASSROOM 8 SINK	0.015	TNR/BS
L6439858-4	CLASSROOM 11 SINK	ND	TNR
L6439858-5	CLASSROOM 10 SINK	ND	TNR
L6439858-6	CLASSROOM 12 SINK	ND	TNR
L6439858-7	CLASSROOM 13 SINK	0.027	TNR/BS
L6439858-8	CLASSROOM 7 SINK	ND	TNR
L6439858-9	CLASSROOM 9 SINK	0.028	TNR/BS
L6439858-10	TRAILER FOUNTAIN	ND	ND
L6439858-11	WATER FOUNTAIN RIGHT BY MEDIA CENTER	ND	ND
L6439858-12	TRAILER SINK	ND	TNR
L6439858-13	WATER FOUNTAIN LEFT BY MEDIA CENTER	ND	ND
L6439858-14	CLASSROOM 27 FOUNTAIN	ND	ND
L6439858-15	FOUNTAIN BY CLASSROOM 9	ND	ND
L6509864-1	CLASSROOM 2 SINK	0.013	TNR/BS
L6509864-2	FOUNTAIN BY CLASSROOM 21	0.018	BS
L6509864-3	TEACHERS ROOM SINK	0.092	BS
L6509864-4	FOUNTAIN RIGHT BY MAIN OFFICE	ND	ND
L6509864-5	KITCHEN SINK LEFT	ND	ND
L6509864-6	FOUNTAIN BY CLASSROOM 24	ND	ND
L6509864-7	CLASSROOM 20 FOUNTAIN	ND	ND
L6509864-8	CLASSROOM 24 FOUNTAIN	0.108	BS
L6509864-9	CLASSROOM 21 SINK	0.019	TNR/BS
L6509864-10	CLASSROOM 25 SINK	0.018	TNR/BS
L6509864-11	KITCHEN SINK RIGHT	ND	ND
L6509864-12	FOUNTAIN LEFT BY MAIN OFFICE	ND	ND
L6509864-13	KINDERGARTEN FOUNTAIN	ND	ND
L6509864-14	CLASSROOM 23 SINK	ND	TNR
L6509864-15	CLASSROOM 23 FUNTAIN	0.023	BS
L6509864-16	CLASSROOM 21 FOUNTAIN	ND	ND
L6509864-17	CLASSROOM 20 SINK	0.014	TNR/BS
L6509864-18	CLASSROOM 22 SINK	0.012	TNR/BS
L6509864-19	KITCHEN SIDE SINK	0.031	BS
L6509864-20	CLASSROOM 25 FOUNTAIN	ND	ND
L6509864-21	KINDERGARTEN SINK	0.017	BS

**PINES LAKE ELEMENTARY  
511 PINES LAKE DRIVE**

Test Date - 10/7/16 & 10/11/16 & 10/13/16

**KEY:**

**TNR: Testing Not Required**  
**ND: None Detected      BS: Below DEP/EPA Standard**  
**DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION**

L6509864-22	KITCHEN SMALL SINK	ND	ND
L6509864-23	BOYS ROOM SINK 3	0.015	TNR/BS
L6509864-24	CLASSROOM 1 SINK	0.044	TNR/BS
L6509864-25	CLASSROOM 2 SINK	0.013	TNR/BS
L6509864-26	FOUNTAIN BY ART ROOM	ND	ND
L6509864-27	BOYS ROOM SINK 2	0.029	TNR/BS
L6509864-28	BOYS ROOM SINK 1	0.048	TNR/BS
L6509864-29	FOUNTAIN RIGHT BY ROOM 35	ND	ND
L6509864-30	FOUNTIAN LEFT BY ROOM 35	ND	ND
L6509864-31	MEDIA CENTER SINK	ND	ND
L6509864-32	CLASSROOM 3 SINK	0.022	TNR/BS
L6509864-33	MAIN OFFICE SINK	ND	TNR/BS
L6509864-34	FOUNTAIN BY TEACHERS ROOM	ND	ND
L6509864-35	TEACHERS ROOM SINK	ND	ND
L6509864-36	NURSES OFFICE SINK	0.016	TNR/BS
L6509864-37	TEACHERS ROOM BATHROOM SINK	ND	ND